



TECHNICAL SESSION

Developing Drought Immunity: The Hamby WRF Potable Water Reuse Project



Joshua L. Berryhill, P.E., Enprotec / Hibbs & Todd, Inc. (eHT)

John Holton, City of Abilene

Stephen Katz, P. Eng. Suez

Kathleen Peach, Suez



Overview

- City of Abilene's Water Supplies
- City of Abilene's Response to Dwindling Water Supplies
- Background on Hamby Water Reclamation Facility
- Details of Planned Indirect Potable Reuse Project
- Hamby WRF Facility Data and Lessons Learned



City of Abilene's Water Supplies



Abilene's Water Utilities

- Abilene serves treated potable water to approximately 125,000 retail users and an additional 32,000 wholesale users.
 - Abilene has approximately 40,000 retail connections and connections with 14 wholesale water systems.
- Abilene supplies reclaimed water to 25 contracted reclaimed customers citywide and an additional 10 irrigators around the Hamby Water Reclamation Facility.
- Abilene diverts approximately 24,500 ac-ft/yr of surface water from its three surface water sources (about 22 MGD) and delivers 23,700 ac-ft/yr to its retail and wholesale customers (about 21 MGD)
- Abilene's retail customers use about 86% (about 18 MGD) of the total treated water that is produced from the water production system while its wholesale customers use about 14% (about 3 MGD)



City of Abilene

Water Production and Wastewater Reuse Schematic (Before January 2015)

Hubbard Creek Reservoir



Lake Fort Phantom Hill



Northeast WTP



Grimes WTP

Hamby WRF



Outfall 001
Freewater Creek



Outfall 002
Kirby Lake



Reuse
Customers

Hargesheimer WTP



Lake O.H.
Ivie




Abilene's Water Sources

- The recent historic drought severely affected Abilene's raw water sources.




Abilene's Water Sources



Lake Fort Phantom Hill

Full pool: 1,635.9 ft msl


2015: - 16.85 ft



Hubbard Creek Lake

Full pool: 1,183.0 ft msl

2015: - 30.73 ft



Lake O.H. Ivie

Full pool: 1,1,551.5 ft msl

2015: - 44.81 ft




City of Abilene's Response to Dwindling Water Supplies



City of Abilene

Water Production and Wastewater Reuse Schematic (After January 2015)



Background on Hamby Water Reclamation Facility



Hamby WRF (Prior to IPR Project)

- The Hamby WRF was constructed in the 1950s and underwent some modifications over the years but represented a first generation activated sludge facility (1970s technology).
- Effluent from the Hamby WRF was usually suitable for discharge to Freewater Creek, and for irrigation reuse, but unsuited for indirect potable reuse.



Hamby WRF (Pre-2015)



Details of Planned Indirect Potable Reuse Project



Indirect Potable Reuse Project

- Constituents of concern in the Hamby WRF effluent, were it to be used for indirect potable reuse included:
 - Nitrogen/Phosphorus-algae growth leads to taste and odor
 - Salinity levels and other secondary parameters
 - DBPs - TTHMs, HAA5, Bromate, others?
 - Contaminants of Emerging Concern (CECs)



Indirect Potable Reuse Project

- The City undertook a study to evaluate treatment options to address needs to:
 - Meet current and future TPDES permits (CBOD5, TSS, ammonia, pH, DO), and to reduce phosphorus.
 - Preserve reuse water quality
 - Remove salinity and other constituents that didn't belong in a drinking water source.



WRF Improvements to Support IPR


- The City determined through its study that a viable treatment system to meet all treatment objectives would utilize:
 - Reverse Osmosis (RO) to reduce salinity and other secondary constituents.
 - Ozone followed by biologically active filters to break apart and remove CECs.
 - Biological Nutrient Removal (BNR) and Membrane Bioreactors (MBR) to meet current and future TPDES permits, to reduce phosphorus, and to provide filtration for Type I/II reuse supply.




Hamby Water Reclamation Facility (During Construction)




Pretreatment System




Flow Equalization System




Biological Nutrient Removal System




Membrane Bioreactor System



Advanced Treatment System



AT System - Chemical Feed Locations



Hamby WRF Facility Data and Lessons Learned



Average and Design WRF Influent Quality for the IPR Project

| Parameter | Average Condition | Design Condition |
|--|-------------------|------------------|
| BOD ₅ (mg/L) | 199 | 232.8 |
| Total Suspended Solids (TSS) (mg/L) | 190 | 226.1 |
| Ammonia (mg/L as N) | 22.0 | 24.0 |
| Total Phosphorus (TP) (mg/L as P) | 5.7 | 7.3 |
| Volatile Suspended Solids (VSS): TSS | 0.70 | 0.70 |
| Ammonia: Total Kjeldahl Nitrogen (TKN) | 0.69 | 0.69 |
| Ortho-Phosphate: TP | 0.5 | 0.5 |



Anticipated TPDES Permit Limits and Reuse Quality Standards

| Parameter | Anticipated Outfall No. 001/002 TPDES Permit Limits | Anticipated Outfall 003 TPDES Permit Limits | Current Type I Reuse Quality Standards per Reclaimed Water Rules |
|---|---|---|--|
| 5-day CBOD ₅ , mg/L | April-Sept.: 7 Oct.-March: 10 | 5 | 5 |
| TSS, mg/L | 15 | 15 | None |
| Ammonia-Nitrogen, (NH ₃ -N), mg/L | April-Sept.: 2 Oct.-March: 3 | 2 | None |
| Total Phosphorus, mg/L | 0.5 | 0.5 | None |
| <i>Escherichia coli</i> (<i>E. coli</i>) CFU/100 mL | <i>E. coli</i> : 126 | <i>E. coli</i> : 126 | Fecal: 20 (30-day geo. mean) 75 (single grab max) |
| Turbidity, NTU | None | None | 3 |



Treatment Goals for Advanced Treated Effluent Discharged Via Outfall No. 003

| Parameter | Goal |
|--|---------------------------|
| Annual Average Flow Rate to Lake Fort Phantom Hill | 7 MGD |
| Total Phosphorus | 0.5 mg/L |
| TDS | 375 mg/L |
| Chloride (as Cl ⁻) | 100 mg/L |
| Sulfate (as SO ₄ ²⁻) | 95 mg/L |
| Pathogen Removal/Inactivation ^b <i>Cryptosporidium parvum</i> <i>Giardia lamblia</i> Viruses | 4-log 4-log 0.5-log |
| Contaminants of Emerging Concern (CECs) | 50 - 90% Reduction |




Comparison of Advanced Treated Effluent Treatment Goals and Actual Performance


| Parameter | Goal | Actual Performance |
|---|--------------------|--------------------|
| Total Phosphorus | 0.5 mg/L | 0.03 mg/L |
| TDS | 375 mg/L | 325 mg/L |
| Chloride (as Cl ⁻) | 100 mg/L | 80 mg/L |
| Sulfate (as SO ₄ ²⁻) | 95 mg/L | 70 mg/L |
| Pathogen Removal/Inactivation ^b | | |
| <i>Cryptosporidium parvum</i> | 4-log | 3.0-5.0-log |
| <i>Giardia lamblia</i> | 4-log | 3.3-5.4-log |
| Enterovirus | 0.5-log+ | 7.1-8.1-log+ |
| Norovirus (all three types) | 0.5-log+ | 4.9-7.2-log+ |
| Contaminants of Emerging Concern (CECs) | 50 - 90% Reduction | 80% Reduction |




MBR Loading Since Reuse Project



Typical MBR Train Performance



Comparison of Historical and Reuse Performance on Total Phosphorus Reduction



For more information, please contact:

Joshua Berryhill, P.E.
Enprotec / Hibbs & Todd, Inc.
joshua.berryhill@e-ht.com

