

March 20, 2024

**CITY OF MASON, TEXAS  
TXCDBG SMITH ST LIFT STATION IMPROVEMENTS**

**Addendum No. 1**

Attention is called to the following modifications to the referenced Plans, Specifications and Contract Documents for the above referenced project. The City of Mason, Texas will receive sealed bids for the TXCDBG Smith St Lift Station Improvements Project until **2:00 p.m., local time on Thursday, April 4, 2024**, at the City of Mason City Hall, located at 124 Moody Street, Mason, Texas 76856. Proposals will be publicly opened and read aloud at this time. We hereby modify the documents as follows:

**CONTRACT:**

1. **REPLACE** all references to the proposed bid opening dates in the Contract Documents from March 20, 2024, with **Thursday, April 4, 2024**, at 2:00 p.m.
2. Article 4. Performance: **REPLACE** all references the time of completion of work from One-Hundred (100) calendar days with 300 calendar days for substantial completion and 330 calendar days for final completion.

**PLANS:**

1. Sheet 4: Lift Station Plan and Section: Lift Station Section 1 – **MODIFY** the note on the discharge pipe as follows: "4" 316 STAINLESS STEEL DISCHARGE PIPE."

**CLARIFICATIONS:**

1. Contractor to be responsible for haul off and disposal of excess excavation material. Contractor may use land areas located at the City of Mason landfill for staging and/or stockpiling excess materials, including excavations. The landfill is located approximately 1.5 miles from the project site.
2. Contractor may utilize City property around the landfill, which is currently unused as a laydown and material storage area.
3. The City will be willing to shut down Smith Street as required for the completion of the work on the Lift Station; however, access must be maintained for residents living along Smith Street.
4. The City owns and operates the electrical services within the City limits and will be willing to work the Contractors to ensure a safe working environment around electrical mains.

This addendum consists of one (1) page and becomes a part of the referenced plans, specifications and contract documents and shall be acknowledged by the proposer and attached to the proposal packet submitted.

By   
Colden S. Rich, P.E.  
Vice President

3/20/24

