

April 30, 2024

**CITY OF MASON, TEXAS  
TXCDBG SMITH STREET LIFT STATION IMPROVEMENTS**

**Addendum No. 1**

Attention is called to the following modifications to the referenced Plans, Specifications and Contract Documents for the above referenced project. The City of Mason, Texas will receive sealed bids for the TXCDBG Smith Street Lift Station Improvements REBID Project until **2:00 p.m., local time on Thursday, May 9, 2024**, at the City of Mason City Hall, located at 124 Moody Street, Mason, Texas 76856. Proposals will be publicly opened and read aloud at this time. We hereby modify the documents as follows:

**CONTRACT:**

1. Proposal: Proposal Page #4 – **REPLACE** Paragraph 2 in its entirety with the following:

The undersigned bidder agrees that he will furnish and install all materials within three-hundred thirty (330) calendar days after the date of the "Notice to Proceed".

**ADDITIONAL APPROVED MANUFACTURERS:**

1. Specification Section 02722 – AK Industries, Inc. shall be **ADDED** as an approved manufacturer for the FRP wetwell.
2. Specification Section 11307 – Homa shall be **ADDED** as an approved manufacturer for lift station pumps.

**CLARIFICATIONS:**

1. An FRP valve vault will be acceptable in accordance with Specification Section 02722.2.3.1.

This addendum consists of one (1) page and becomes a part of the referenced plans, specifications and contract documents and shall be acknowledged by the proposer and attached to the proposal packet submitted.

  
By \_\_\_\_\_  
Colden S. Rich, P.E.  
Vice President

4/30/24

