



December 6, 2024

City of Big Lake, Texas
High Service Pump Station Pump Replacement

Addendum No. 1

Attention is called to the following modifications to the Plans, Specifications and Contract Documents (collectively Proposal Documents) for the above referenced project. The City of Big Lake will receive sealed Proposals for the High Service Pump Station Pump Replacement Project, until **4:30 p.m.** local time on **Tuesday December 17, 2024**, at City Hall located at 203 Plaza, Big Lake, Texas 76932. Proposals will be publicly opened and read aloud. We hereby modify the documents as follows:

PROPOSAL DOCUMENTS:

1. Price Proposal Sheet: Items 2 and 5 – **DELETE** “including pump can inspection and rehabilitation”.

SPECIFICATIONS:

1. Section 01010 – Summary of Work: **REMOVE** Section 1.1.A.3 in its entirety.

DRAWINGS:

1. **REVISE** page 3 of 4 as follows:

Mechanical Key Notes 1 and 2:

1. **REMOVE** “REHABILITATE PUMP CAN AS NECESSARY”
2. **REMOVE** “REHABILITATE PUMP CAN AS NECESSARY”

It is not currently requested for the contractor rehabilitate the canisters under this contract. If it is determined during construction that rehabilitation of the canisters is needed, a change order allocating more funds can be negotiated.

CLARIFICATIONS:

1. Attached is a drawing of the existing pump station, for reference with the existing Drawing Sheets. The attached drawing should only be used for a dimensional analysis of the existing pump canisters.
2. Please use the attachment as a dimensional drawing, but sizing of the existing canister could vary depending on prior wear and usage.

This addendum consists of **two (2)** pages and becomes a part of the referenced plans, specifications and contract documents and **SHALL BE ACKNOWLEDGED** by the Proposer and attached to the Proposal submitted.


By: Sage Diller, P.E. #96645
Vice President

PE Firm Registration No. 1151
PG Firm Registration No. 50103
RPLS Firm Registration No. 10011900



12/6/2024