

April 8, 2025

**CITY OF SWEETWATER
WATER SYSTEM IMPROVEMENTS
CONTRACT B – RAW WATER AND BOOSTER PUMP STATION REHABILITATION
TEXAS WATER DEVELOPMENT BOARD (TWDB) DWSRF PROJECT NO. 62897**

Addendum No. 3

Attention is called to the following modifications to the referenced Plans, Specification and Contract Documents for the above referenced project. The City of Sweetwater will receive sealed Bids for the TWDB DWSRF #62897, Water System Improvements, Contract B – Raw Water and Booster Pump Station Rehabilitation Project at Sweetwater City Hall, located at 200 E. 4th Street, Sweetwater, Texas 79556, until **3:00 p.m.**, local time on **Thursday, April 10, 2025**, at which time the sealed Bids received will be publicly opened and read. We hereby modify as follows:

CLARIFICATIONS


1. Stand alone VFDs, motor starters, and panelboard in lieu of motor control center is acceptable.
2. Siemens electrical equipment is acceptable.
3. New transformer utility pole shown on Sheet E-3 will be provided by Utility, and shall not be included in the price of ITEM NO 3.


DRAWINGS

1. Sheet No. E-3, Note 10. **CHANGE** Note 10 to “EXISTING CONDUIT ROUTED BELOW THE BRIDGE TO THE PUMP STATION SHALL BE ABANDONED IN PLACE.”
2. Sheet No. G-7, Note 4. **CHANGE** Note 4 to “INSTALL METAL PLATE TO COVER WINDOW OPENINGS. WHERE NEW HVAC UNIT IS INSTALLED, PLATES ARE TO BE CUT TO ACCOMMODATE SUPPLY AND RETURN VENTS.”
3. Sheet No. G-11, Note 4. **CHANGE** Note 4 to “INSTALL METAL PLATE TO COVER WINDOW OPENINGS. WHERE NEW HVAC UNIT IS INSTALLED, PLATES ARE TO BE CUT TO ACCOMMODATE SUPPLY AND RETURN VENTS.”

This addendum consists of one (1) page and becomes a part of the referenced plans, specifications and contract documents and shall be acknowledged by the proposer and attached to the sealed proposal submitted.

By: 
Leroy Arce, P.E. #114163
Project Manager



By: 
Donald S. Mattern, P.E. #106161
Project Manager

