



August 8, 2025

**CITY OF TOLAR, TEXAS  
NORTH PUMP STATION PROJECT**

**Addendum No. 2**


Attention is called to the following modifications to the referenced Plans, Specification and Contract Documents for the above referenced project. The City of Tolar (City) will receive sealed Proposals for the North Pump Station Project at **Tolar City Hall** located at **8712 W. Highway 377, Tolar, Texas 76476**, until **Tuesday, August 12<sup>th</sup>, 2025**, at **2:00 p.m.** local time. We hereby modify the documents as follows:

**SPECIFICATIONS:**

1. **MODIFY** Section 13205 Ground Storage Tanks to **ADD** a new Item G under "1.3 Design Requirements" to state:

G. Tank Dimensions: Tank Manufacturer shall determine final tank dimensions. Allowable tank diameter shall range from what is shown on the Drawings up to twenty-two feet (22') in diameter. Tank height can be adjusted as necessary due to the final tank diameter but shall maintain same free board capacity as shown on the Drawings and minimum capacity (volume) as required by the Drawings and Specifications.

This addendum consists of one (1) page and becomes a part of the referenced plans, specifications and contract documents and shall be acknowledged by the proposer and attached to the sealed proposal submitted.

  
By \_\_\_\_\_  
Chris Hay, P.E.  
Project Engineer

